



Consumer Confidence Report TCEQ Certificate of Delivery
Texas Commission on Environmental Quality

For Calendar year: 2019
PWS ID Number: 109001

Date Distributed to Customers: 6-29-2020
PWS Name: City of Hillsboro

You must use at least one direct delivery and at least one good faith delivery method. If your system is under 500 population, please use Small System Certificate of Delivery form.

Direct Delivery Methods

- ☐ Mail a paper copy of the CCR
- ☐ Mail notification that CCR is available on-line at <http://> _____
- *The Internet link (url) you insert above must take customers directly to the open CCR.
- ☒ Email direct web address of the CCR, available at http://www.HillsboroTX.org/wpr_content/uploads/
- ☐ Email CCR as an attachment to or an embedded image in an email. 2020/06/CCR 2019-completed.pdf
- ☐ Other direct delivery (for example, door hangers or additional electronic delivery method).
Please specify: _____

Systems serving 100,000 or more people are required to post the CCR on a publicly available web site and provide the direct URL here: <http://> _____

Good faith delivery methods (To reach people who do not receive bills)

- ☒ Posting the CCR on the Internet at [http://www.Hillsboro.org/city Department water-wastewater](http://www.Hillsboro.org/city_department_water-wastewater)
- ☐ Mailing the CCR to people who receive mail, but who do not receive bills.
- ☐ Advertising the availability of the CCR in news media.
- ☒ Posting the CCR in public places.
- ☐ Delivering multiple copies to single billing addresses serving multiple persons.
- ☐ Delivering multiple copies of the CCR to community organizations.

I certify that the community water system named above has distributed the Consumer Confidence Report (CCR) for the calendar year of 2019 and that the information in the report is correct and consistent with the compliance monitoring data previously submitted to the TCEQ. Systems serving 100,000 or more people are required to post the CCR on a publicly available web site and provide the direct URL.

Certified By:

Name (print): Walter Garcia Title: Director of Public Works Phone Number: 1-254-266-5441
Signature: [Signature] Date: 6-25-2020

All systems are required to mail by July 1 the Certificate of Delivery and Consumer Confidence Report to:

Sending by certified mail:	Sending by regular mail:
TCEQ DWSF, MC-155, Attn: CCR, 12100 Park 35 Circle Austin, TX 78753	TCEQ DWSF, MC-155, Attn: CCR, PO Box 13087 Austin, TX 78711-3087

2019 Consumer Confidence Report for Public Water System CITY OF HILLSBORO

PWS 1090001

This is your water quality report for January 1 to December 31, 2019

CITY OF HILLSBORO provides surface water from Lake Aquilla located in Hill County.

For more information regarding this report contact:

Name: Walter García

Phone: (254) 582-3478

Este reporte incluye información importante sobre el agua para tomar. Para asistencia en español, favor de llamar al telefono (254) 582-3478.

Definitions and Abbreviations

Definitions and Abbreviations

Action Level:

Action Level Goal (ALG):

Avg:

Level 1 Assessment:

Level 2 Assessment:

Maximum Contaminant Level or MCL:

Maximum Contaminant Level Goal or MCLG:

Maximum residual disinfectant level or MRDL:

Maximum residual disinfectant level goal or MRDLG:

MFL

mrem:

na:

NTU

pc/l

The following tables contain scientific terms and measures, some of which may require explanation.

The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

The level of a contaminant in drinking water below which there is no known or expected risk to health. ALGs allow for a margin of safety.

Regulatory compliance with some MCLs are based on running annual average of monthly samples.

A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.

A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an E. coli MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.

The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

million fibers per liter (a measure of asbestos)

millirems per year (a measure of radiation absorbed by the body)

not applicable.

nephelometric turbidity units (a measure of turbidity)

picocuries per liter (a measure of radioactivity)

Definitions and Abbreviations

ppb:	micrograms per liter or parts per billion - or one ounce in 7,350,000 gallons of water.
ppm:	milligrams per liter or parts per million - or one ounce in 7,350 gallons of water.
ppq	parts per quadrillion, or picograms per liter (pg/L)
ppt	parts per trillion, or nanograms per liter (ng/L)
Treatment Technique or TT:	A required process intended to reduce the level of a contaminant in drinking water.

Information about your Drinking Water

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPAs Safe Drinking Water Hotline at (800) 426-4791.

Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, and septic systems.
- Radioactive contaminants, which can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Contaminants may be found in drinking water that may cause taste, color, or odor problems. These types of problems are not necessarily causes for health concerns. For more information on taste, odor, or color of drinking water, please contact the system's business office.

You may be more vulnerable than the general population to certain microbial contaminants, such as *Cryptosporidium*, in drinking water. Infants, some elderly, or immunocompromised persons such as those undergoing chemotherapy for cancer; persons who have undergone organ transplants; those who are undergoing treatment with steroids; and people with HIV/AIDS or other immune system disorders, can be particularly at risk from infections. You should seek advice about drinking water from your physician or health care providers. Additional guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* are available from the Safe Drinking Water Hotline (800-426-4791).

if present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. We are responsible for providing high quality drinking water, but we cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

Information about Source Water

CITY OF HILLSBORO purchases water from AQUILLA WSD. AQUILLA WSD provides purchase surface water from Lake Aquilla in Hill County.

'[Insert a table containing any contaminant that was detected in the provider's water for this calendar year, unless that contaminant has been separately monitored in your water system (i.e. TTHM, HAA5, Lead and Copper, Coliforms)]':

'No Source Water Assessment for your drinking water source(s) has been conducted by the TCEQ for your water system. The report describes the susceptibility and the types of constituents that may come into contact with your drinking water source based on human activities and natural conditions. The information in this assessment allows us to focus our source water protection strategies.'

Coliform Bacteria

Maximum Contaminant Level Goal	Total Coliform Maximum Contaminant Level	Highest No. of Positive	Fecal Coliform or E. Coli Maximum Contaminant Level	Total No. of Positive E. Coli or Fecal Coliform Samples	Violation	Likely Source of Contamination
0	1 positive monthly sample.	1	1	0	N	Naturally present in the environment.

Lead & Copper

Lead and Copper	Date Sampled	MCLG	Action Level (AL)	90th Percentile	# Sites Over AL	Units	Violation	Likely Source of Contamination
Copper	2019	1.3	1.3	0.257	0	ppm	N	Erosion of natural deposits; Leaching from wood preservatives; Corrosion of household plumbing systems.
Lead	2019	0	15	6.47	2	ppb	N	Corrosion of household plumbing systems; Erosion of natural deposits.

2019 Water Quality Test Results

Disinfection By-Products	Collection Date	Highest Level Detected	Range of Individual Samples	MCLG	MCL	Units	Violation	Likely Source of Contamination
Haloacetic Acids (HAA5)	2019	26	16 - 26.8	No goal for the total	60	ppb	N	By-product of drinking water disinfection.

** The value in the Highest Level or Average Detected column is the highest average of all HAA5 sample results collected at a location over a year'

Total Trihalomethanes (TTHM)	2019	12	7.19 - 17.9	No goal for the total	80	ppb	N	By-product of drinking water disinfection.
------------------------------	------	----	-------------	-----------------------	----	-----	---	--

** The value in the Highest Level or Average Detected column is the highest average of all TTHM sample results collected at a location over a year'

Inorganic Contaminants	Collection Date	Highest Level Detected	Range of Individual Samples	MCLG	MCL	Units	Violation	Likely Source of Contamination
Nitrate [measured as Nitrogen]	2019	1	0.185 - 1.41	10	10	ppm	N	Runoff from fertilizer use; leaching from septic tanks, sewage; Erosion of natural deposits.

Disinfectant Residual'

Disinfectant Residual	Year	Average Level	Range of Levels Detected	MIRDL	MIRDLG	Unit of Measure	Violation (Y/N)	Source in Drinking Water
Chloramines	2019	1.32	0.08 – 3.80	4	4	ppm	N	Water additive used to control microbes.

Results from Aquilla Water Supply

Metals	Year	Average Level	Range of Levels Detected	MCL	MCLG	Unit of Measure	Violation (Y/N)	Source in Drinking Water
Aluminum	2019	0.0093	0.0093 – 0.0093	0.05 - 0.2	0	ppm	N	Aluminum can leach from rock and soil to enter any water source. It can be found as aluminum hydroxide, which is a residual from the municipal feeding of aluminum sulfate. It can also be present as sodium aluminate from a process known as clarification or precipitation softening.

Barium	2019	0.041	0.041 – 0.041	2	0	ppm	N	The major sources of barium in drinking water are discharge of drilling wastes; discharge from metal refineries; and erosion of natural deposits.
Nickel	2019	0.0015	0.0015 – 0.0015	0.1	0	ppm	N	The primary source of nickel in drinking-water is leaching from metals in contact with drinking-water, such as pipes and fittings.

Zinc	2019	0.0052	0.0052 – 0.0052	5.0	0	ppm	N	introduced into water naturally by erosion of minerals from rocks and soil, since zinc ores are only slightly soluble in water. Most zinc is introduced into water by artificial pathways such as by-products.
------	------	--------	-----------------	-----	---	-----	---	--

Pesticides	Year	Average Level	Range of Levels Detected	MCL	MCLG	Unit of Measure	Violation (Y/N)	Source in Drinking Water
Atrazine	2019	0.4	0.3 – 0.5	3.0	0	ug/l	N	Soil run-off from application to row crops for weed control.

Metolachlor	2019	0.3	0.0002 – 0.0003	0.525	0	ppm	N	Soil run-off from application to row crops for weed control.
-------------	------	-----	-----------------	-------	---	-----	---	--

Turbidity

Turbidity has no health effects. However, turbidity can interfere with disinfection and provide a medium for microbial growth. Turbidity may indicate the presence of disease-causing organisms. These organisms include bacteria, viruses, and parasites that can cause symptoms such as nausea, cramps, diarrhea, and associated headaches.

Year	Constituent	Highest single Measurement	Lowest Monthly % of samples meeting Limits	Turbidity Limits	Unit of Measure	Annual Average	Source of Constituent
2019	Turbidity	0.90	99.95	0.3	NTU	0.14	Soil Runoff

Violations

Lead and Copper Rule

The Lead and Copper Rule protects public health by minimizing lead and copper levels in drinking water, primarily by reducing water corrosivity. Lead and copper enter drinking water mainly from corrosion of lead and copper containing plumbing materials.

Violation Type	Violation Begin	Violation End	Violation Explanation
LEAD CONSUMER NOTICE (LCR)	12/30/2019	04/02/2020	We failed to provide the results of lead tap water monitoring to the consumers at the location water was tested. These were supposed to be provided no later than 30 days after learning the results.

Public Notification Rule

The Public Notification Rule helps to ensure that consumers will always know if there is a problem with their drinking water. These notices immediately alert consumers if there is a serious problem with their drinking water (e.g., a boil water emergency).

Violation Type	Violation Begin	Violation End	Violation Explanation
PUBLIC NOTICE RULE LINKED TO VIOLATION	03/29/2019	2019	We failed to adequately notify you, our drinking water consumers, about a violation of the drinking water regulations.

The City of Hillsboro, according to the Texas Water Development Board Water Loss Audit, for 2019, Had a water loss of 0000000MG, for 2019

215, 191, 359

WLB. 8-25-2020